

PfB Testing Centre for Construction Elements

08.09.2014

Certificate No. 14/05-A175-Z1

Hygrothermal test



tested in accordance with DIN EN 1121: 2000-09 (test regulation; climate category c and d)

Wellhöfer Attic Stairs

(Type with additional feature thermal protection WS)

i. acc. with DIN EN 1121: 2000-09

Climate category c

Climate category d

i. acc. with DIN EN 12219: 2000-06

Class 3

Class 3

-> The form stability of the attic stairs with thermal protection WS under changing temperature/humidity conditions is better than required for doors of **Class 2**

(i. acc. DIN EN 12219)