

Confirmation

BREEAM[®] NOR 2016

On 11 November 2020, Eurofins Product Testing A/S received a sample of a paint with the product name:

**COLORS FOR LIFE Wall Paints 321, 331, 535,
555, 524**

supplied by

AURO Pflanzenchemie AG

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000-3 -6 -9 -11, EN 16516 and ISO 11890-2 in the latest versions (See test report no. 392-2020-00507401_A_EN and 392-2020-00507402_XI_EN).

The test results of the tested paint indicate that the product qualifies for BREEAM-NOR New Construction 2016 v1.2 (2019) specifications on VOC emissions and VOC content by complying with:

BREEAM NOR 2016 requirements on "Volatile Organic Compounds" in Hea 02 criteria for paints and varnishes

VOC emissions specifications:

- TVOC was below the limit of 200 µg/(m²*h) after 28 days
- Formaldehyde was below the limit of 24 µg/(m²*h) after 3 days
- Formaldehyde was below the limit of 50 µg/(m²*h) after 28 days
- Carcinogenic substances was below the limit of 5 µg/(m²*h) after 28 days

VOC content specifications:

- the requirements of the EU Decopaint Directive 2004/42/CE

2 March 2021



Janne Rothmann Norup
Analytical Service Manager