

Extract from the TÜV Rheinland LGA Products
test report 02.11.2015

Test report no. 21242493001

VOC emissions test



tested, DIN EN ISO 16000, according to the approval regulations for
the health-related assessment of construction products, CEN/TS 16516

Wellhöfer Attic Stairs

28-day test of the **sum total of volatile organic compounds (TVOC)** and **formaldehyde (HCHO)**; target values for harmlessness as specified by the Sentinel Haus Institut.

Emission	Test results	Harmless value according to Sentinel Haus Institut
TVOC:	35 µg/m ³	< 300 µg/m ³
HCHO:	1,5 µg/m ³	< 24 µg/m ³

- > The emissions value of the attic stairs is **over 9x better than the value which is considered to be harmless** as required by the Sentinel Haus Institut.
- > The formaldehyde value of the attic stairs is **over 16x better than the value which is considered to be harmless** as required by the Sentinel Haus Institut.